


# VIBRATION ANALYSIS CASE HISTORY

The logo for Full Spectrum Diagnostics (FSD) is located at the top of the page. It features a stylized waveform on the left, composed of multiple overlapping lines in red, orange, yellow, green, and blue, resembling a spectrum or a vibration signal. To the right of the waveform is the large, bold, black letters 'FSD'. Further to the right, the words 'FULL SPECTRUM DIAGNOSTICS' are written in a smaller, bold, black, sans-serif font. Below this, in a smaller, italicized, black, sans-serif font, is the text 'A Professional Limited Liability Corporation'.



Dan Ambre is the founder of Full Spectrum Diagnostics, (June of 2000) providing the finest in Machinery Condition Monitoring, Specialized Analyses, and Vibration Training for Industrial, Manufacturing, Aerospace, and Automotive applications.

Dan is a graduate of ***The University of Iowa*** with a Bachelor's degree in Mechanical Engineering, and has completed additional graduate level course work in Engineering Dynamics from ***The University of Illinois at Chicago***, and ***Florida Atlantic University***.

Dan has over 30 years experience in the aviation and aerospace industries with a background in Vibration & Acoustic testing, Dynamic analysis of high speed rotor systems, Experimental Modal, and Finite Element Analysis. His consulting vibration experience base comes from positions at Sundstrand Aviation Corporation, Pratt & Whitney (United Technologies Corporation), and Technical Associates of Charlotte.

Dan is a Certified Level III / CAT IV. Vibration Training Instructor and a registered Professional Engineer in Minnesota.

**Machine Class: Feed Water Pump (Nuclear)**

**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**

### **PROBLEM STATEMENT:**

This machine was experiencing Elevated Vibration response at 1x RPM. The dominant response was in the Vertical Direction on the outboard bearing support.

### **PRELIMINARY ASSESSMENT:**



1. Unbalance
2. Coupling Alignment Error (Vertical Offset)
3. Bearing Assembly Alignment Error
4. Natural Frequency excited by Pump 1x RPM response.
5. Amplified Piping Response

### **FINAL CONCLUSIONS:**

1. Natural Frequency excited by Pump Residual 1x RPM response.

### **RECOMMENDATIONS / OPTIONS:**

- Change Rotor Speed to Avoid Resonance
- Add Mass: Reduce Natural Frequency
- Remove Mass: Increase Natural Frequency
- Add Stiffness: Increase Natural Frequency
- Remove Stiffness: Reduce Natural Frequency
- Add Damping: Reduce Resonance Amplification



**Machine Class: Feed Water Pump (Nuclear)**


**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**

### OVERALL RESPONSE:


Overall response showed “step” changes in response in the Vertical Vibration levels at the pump outboard bearing housing. The step changes were associated with maintenance outage unit restarts.

Notations indicate significant structural modifications to this unit. There appears to be a shift in amplitude that is associated with each recent change.




### SPECTRUM RESPONSE:

The Spectrum response shown indicates a dominant 1x rotor speed (5,100 RPM / 85 Hz) vertical vibration level at the pump outboard bearing location. Also shown is the Blade Passing Frequency (BPF) at 5x RPM.




### TIME WAVEFORM RESPONSE:

The Time Waveform shows a dominant synchronous response with a slight higher frequency distortion due to the 5x RPM blade passing frequency.




# The VIBRATION FAULT PERIODIC TABLE







# The VIBRATION FAULT PERIODIC TABLE



# The VIBRATION FAULT PERIODIC TABLE




# The VIBRATION FAULT PERIODIC TABLE






# The VIBRATION FAULT PERIODIC TABLE







# The VIBRATION FAULT PERIODIC TABLE



# The VIBRATION FAULT PERIODIC TABLE




# The VIBRATION FAULT PERIODIC TABLE






# The VIBRATION FAULT PERIODIC TABLE



# The VIBRATION FAULT PERIODIC TABLE



**Overall Alarm: 0.400 ips**



**Overall Alarm: 0.400 ips**

### Potential Causes:

## ~~M<sub>bd</sub>—Belt Drive Misalignment~~



~~$C_{bi}$  — Cocked Bearing Inner Race~~

**N<sub>f</sub>    Natural Frequency / Resonant Amplification**

48 mechanical engineering symbols are displayed, each in a colored box with a number, a symbol, a description, and a unit. The symbols include:

- U<sub>b</sub>** (UNBAL)
- E<sub>c</sub>** (ECCENTR)
- M<sub>o</sub>** (ALIGN OFFSET)
- L<sub>a</sub>** (LOOSE TYPE A)
- B<sub>s</sub>** (BENT SHAFT)
- G<sub>th</sub>** (GEAR TOOTH)
- M<sub>a</sub>** (ALIGN 19 ANGULAR)
- U<sub>o</sub>** (OVERHUNG UNBAL)
- C<sub>bo</sub>** (COCK BRG OUTER)
- M<sub>bd</sub>** (ALIGN BELT DRIVE)
- C<sub>bi</sub>** (COCK BRG INNER)
- E<sub>rb</sub>** (ROTOR BAR)
- H<sub>lb</sub>** (LUB TYPE B)
- R** (RUB)
- W<sub>h</sub>** (OIL WHGL)
- W<sub>p</sub>** (OIL WHIP)
- B<sub>or</sub>** (RES OUT FACE)
- B<sub>sp</sub>** (RES BLE SPN)
- B<sub>ar</sub>** (ROLL BARRING)
- G<sub>ap</sub>** (ASSEN PHASE)
- B<sub>f</sub>** (BELT FREQ)
- T<sub>b</sub>** (TURB FLOW)
- N<sub>f</sub>** (NATURAL FREQ)
- B<sub>ir</sub>** (RES INNER FACE)
- B<sub>n</sub>** (RES BARRING FREQ)
- F<sub>l</sub>** (FLUTING)
- G<sub>lo</sub>** (LOOSE TYPE C)
- B<sub>f</sub>** (BELT FREQ)
- T<sub>b</sub>** (TURB FLOW)
- E<sub>if</sub>** (ELECTR FREQ)
- B<sub>c</sub>** (RES CAGE FREQ)
- H<sub>rb</sub>** (ROTOR BAR)
- G<sub>ht</sub>** (HUNTING TOOTH)
- S<sub>h</sub>** (SHUNT TOOTH)
- P** (POLE PASSING)
- T<sub>c</sub>** (TURB CAVITATE)
- E<sub>lf</sub>** (ELECTR FREQ)
- B<sub>c</sub>** (RES CAGE FREQ)
- U<sub>s</sub>** (RES CAGE FREQ)
- E<sub>dc</sub>** (ELECTR FREQ)
- B<sub>c</sub>** (RES CAGE FREQ)
- E<sub>p</sub>** (POLE PASSING)
- E<sub>p</sub>** (POLE PASSING)

## BY DESIGN SOME FAULTS ARE RULED-OUT



**Overall Alarm: 0.400 ips**

**Overall Alarm: 0.400 ips**

### Potential Causes:

**N<sub>f</sub>    Natural Frequency / Resonant Amplification**



**Overall Alarm: 0.400 ips**

### Potential Causes:

**N<sub>f</sub>    Natural Frequency / Resonant Amplification**

## 18

**Overall Alarm: 0.400 ips**

### Potential Causes:

**N<sub>f</sub>    Natural Frequency / Resonant Amplification**

[illegible]

Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

# FEED WATER PUMP HISTORY

## SYNCHRONOUS VIBRATION [1x RPM]

Potential Causes:

### Natural Frequency / Resonant Amplification

Current Motion Indicates Vertical Pitching Mode

2005



EMA defined HORIZONTAL Torsional Mode @ 5,112 RPM [1x].  
This Resonance is Resolved by Structural Modification

2005

EMA defined a VERTICAL PITCHING MODE @ 4,200 CPM  
[>20% Resonance Margin] Recommended Pedestal Structural  
Modification is NOT expected to alter this mode.

2015

The 2005 Vertical Pitching Mode at 4,200 CPM is suspected to  
be stiffened into the Operating Speed Range due to Large  
Piping Line (2014) and/or Foundation Modifications (2012)  
associated with the shifts in Vertical Overall Vibration  
response.





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

# ANALYSIS & TESTING PROPOSAL

## **REVIEW** 2005 Experimental Modal Analysis

Data / Analysis / Methodologies / Assumptions / Conclusions

## **PERFORM** Operating Modal Analysis (OMA) on FW-P-32B

Determine Current Natural Frequencies, Mode Shapes

## **CONSTRUCT** Finite Element Analysis (FEA) Model of Pump

Use 2005 EMA and 2015 OMA Analyses for Correlation of Modes and Mode Shapes

Use FEA Model to **DEFINE** Structural Modifications to Eliminate or Reduce 1x RPM Vibration Response

Stiffness / Mass / Damping / Phase Cancellation

## **VERIFY** Natural Frequencies and Mode Shapes during Maintenance Outage (OR17)

Shutdown Experimental Modal Analysis

Post-Modification EMA


## **PERFORM** Start-up Operating Modal Analysis (OMA) on FW-P-32B

Monitor Natural Frequencies, Mode Shapes

Verify Modification Results

Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

## 2005 EXPERIMENTAL MODAL ANALYSIS



### REVIEW 2005 Experimental Modal Analysis

Data / Analysis / Methodologies / Assumptions / Conclusions

## Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

### EXPERIMENTAL MODAL ANALYSIS:

Experimental Modal Analysis (EMA) is also known as “Impact” or “Impulse” Natural Frequency Analysis. The empirical test method is a static diagnostic performed on structures to determine their natural frequencies, damping, and mode shapes. This analysis is performed with the machinery in a non-operating condition with limited background vibration from other machinery sources.




An impulse (usually a hammer blow) is applied to the structure to impart broad-band energy to the system. This energy functions to excite all of the system natural frequencies, similar to the response of a bell or tuning fork to a sharp impact. This hammer has a load cell built into the head that measures the force imparted to the structure and allows this signal to be compared to the accelerometer response, via a transfer function, resulting in a measurement of the frequency response of the structure. Given enough response locations, each system natural frequency can be curve fit and its mode shape animated with specialized modal analysis software.

This testing was performed on the FW-P-32-B unit in each directional axis (x, y, z) separately to ensure that each mode in the operating range would be excited. The resulting data reflects mode shapes in these three dominant directions.

The x-axis is along the shaft centerline.

The y-axis is in the pump horizontal direction.

The z-axis is in the vertical pump direction.




Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)**
- 5 98.3 Hz Torsion (y, z)




### EXPERIMENTAL MODAL ANALYSIS:

The 2005 Vibration Analysis included an Experimental Modal Analysis with the FWP32B in a non-operating condition. The analysis defined several natural frequencies in the system.

A Torsional Mode of the pump was detected within 1% of the normal operating speed @ 85 Hz (5,100 RPM). Excitation of this mode by residual unbalance and alignment forces created an elevated response in the horizontal direction.

The response could be detected at each bearing but was dominant at the pump outboard bearing. The Overlaid Measurement data set below shows a Magnitude Response and Phase Angle Response (Bode Plot).






Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis      Modifications      Margin

1	37.7 Hz	→	44.0 Hz	-48.2 %
2	43.7 Hz	→	53.3 Hz	-37.3 %
3	69.9 Hz	→	70.7 Hz	-16.8 %
4	85.2 Hz	→	92.0 Hz	+ 8.0 %
5	98.3 Hz	→	106 Hz	+24.7 %




### EXPERIMENTAL MODAL ANALYSIS:

The analysis at that time predicted that a gusset design similar to the one shown here would provide sufficient stiffness to push the torsional mode out of the operating speed range and reduce the horizontal vibration to acceptable levels.

The Actual Gusset Design (shown on right) was projected to provide the frequency margins shown in the table above. Typically, a margin of +/- 10% is desired.

Note that the (Vertical Pitching ) mode at 69.9 Hz was not expected to increase due to the gusset modification, which was designed to restrict only the “torsional” response.



**Machine Class: Feed Water Pump (Nuclear)**

**Rotating Speed: 5100 RPM**


**Overall Alarm: 0.400 ips**

### THE CAMPBELL DIAGRAM:

A Campbell Diagram, also known as an Interference Diagram, allows the user to visually plot rotating orders of machinery versus natural frequencies in the system to determine if a coincidence situation exists, or more plainly, to determine potential resonance drivers in the system.

This diagram is a plot of Frequency (Natural Frequency) in CPM units versus Frequency (Rotational Speed) in RPM units. The natural frequencies of the Machine or Structures are defined from Experimental Modal testing and plotted as horizontal lines on the diagram. The operational speed frequency ranges are defined and plotted as a vertical range on the diagram. Rotating orders of running speed (1x, 2x, 3x, ...nx RPM) are plotted as sloping lines. The 1x RPM line has a 1:1 slope, the 2x RPM line has a 2:1 slope, and each higher harmonic follows the same characteristic.

Crossings of the rotating orders (1x, 2x, ...RPM) and the plotted natural frequencies within the operating speed ranges indicate possible resonance concerns that may impact the vibratory amplitudes in the system. Note that mechanical systems are designed with rotating speed margin (difference) on natural frequencies to reduce amplification due to resonance.




Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM


Overall Alarm: 0.400 ips

Use Arrow Keys or Space Bar to Advance Graphics



## 2005 EMA Analysis: Campbell Diagram

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)**
- 5 98.3 Hz Torsion (y, z)







Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)
- 5 98.3 Hz Torsion (y, z)





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis

- 1 **37.7 Hz Rigid Body (y)**
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)
- 5 98.3 Hz Torsion (y, z)





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)**
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)
- 5 98.3 Hz Torsion (y, z)





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)**
- 4 85.2 Hz Torsion (z)
- 5 98.3 Hz Torsion (y, z)







Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2005 EMA Analysis

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)**
- 5 98.3 Hz Torsion (y, z)





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips


## 2005 EMA Analysis

- 1 37.7 Hz Rigid Body (y)
- 2 43.7 Hz Rigid Body (x, y)
- 3 69.9 Hz Vert Pitch (z)
- 4 85.2 Hz Torsion (z)
- 5 98.3 Hz Torsion (y, z)**



Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

## 2015 OPERATING MODAL ANALYSIS



**PERFORM** Operating Modal Analysis (OMA) on FW-P-32B  
Determine Current Natural Frequencies & Mode Shapes

**Machine Class: Feed Water Pump (Nuclear)**


**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**


## OPERATING MODAL ANALYSIS:

Operating Modal Analysis is an analysis method used to extract resonant frequencies, damping, and/or operating shapes (un-scaled mode shapes) of a structure. This method sometime called output-only modal analysis because only the response of the structure is measured. The structure might be excited using natural operating conditions or some other excitations might be applied to the structure; however, as long as the operating shapes are not scaled based on the applied force, it is called operational modal analysis.

The operating characteristics of the Feed Water Pump include a sufficient level of “random” background response from turbulent steam flow and rotor energy. If this low-level background noise is processed with significant averaging, the Modal Frequencies and Mode Shapes can be extracted from the final data. This OMA is referred to here as a “**Non-Impulse Operating Modal Analysis.**”



### Vertical Pitching Mode: 85 Hz





Machine Class: Feed Water Pump (Nuclear)


Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## OPERATING MODAL ANALYSIS:


Operating Modal Analysis is an analysis method used to extract resonant frequencies, damping, and/or operating shapes (un-scaled mode shapes) of a structure. This method sometime called output-only modal analysis because only the response of the structure is measured. The structure might be excited using natural operating conditions or some other excitations might be applied to the structure; however, as long as the operating shapes are not scaled based on the applied force, it is called operational modal analysis.

The 2015 Vibration Analysis also included an Experimental Modal Analysis Impact Test with the FWP32B in an operating condition. This analysis is sometimes called an Operating Modal Analysis. Here it is referred to as an “**Impulse Operating Modal Analysis.**”




## Vertical Pitching Mode: 85 Hz

## Impulse OMA




Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips


## 2015 FINITE ELEMENT ANALYSIS




Trial #1




Trial #2



Trial #3



Trial #4



Trial #5

### **CONSTRUCT** Finite Element Analysis (FEA) Model of Pump

Use 2005 EMA and 2015 OMA Analyses for Correlation of Modes & Mode Shapes

Use FEA Model to **DEFINE** Structural Modifications to Eliminate or Reduce 1x RPM  
Vibration Response: Stiffness / Mass / Damping / Phase Cancellation

**Machine Class: Feed Water Pump (Nuclear)**



**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**

### **FINITE ELEMENT ANALYSIS:**

Finite Element Analysis, or FEA, is a numerical computer modeling method of analysis used for structural design and evaluation. This analysis involves the creation of a computer representation of a structure or machine. The representation consists of points, lines, and surfaces that define the elements, or three-dimensional volume(s) of the component under investigation.

Additional engineering material(s) properties information in the form of Mass Density (lb/in<sup>3</sup>), Modulus of Elasticity (lb/in<sup>2</sup>), Shear Modulus (lb/in<sup>2</sup>), and Poisson's Ratio are assigned to the elements. As well as artificial stiffness, added mass and flexibilities to simulate their boundary (mounted) conditions. If designed correctly, the FEA model can accurately predict the "Modes of Vibration" (natural frequencies) in the analysis structure. FEA models typically require some experimental data for empirical correlation. A common method, as in this case is a natural frequency correlation from an Experimental Modal Analysis.




Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 3600 RPM

Overall Alarm: 0.400 ips

## OPERATING MODAL ANALYSIS:

### Pre-Shutdown Analysis & Testing



Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2% ←
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (y,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

(1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]

(2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed

(3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements

(4) 2015 OMA Analysis (Impulse) Operating EMA Analysis

(5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results

(\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending

(\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.

**Excellent Correlation with 2005 EMA analysis and  
Modified Pedestal Gussets introduced into the FEA model.**

**Except FEA model did NOT Predict the Vertical Pitching Mode  
to move into the operating speed range.**



**Machine Class: Feed Water Pump (Nuclear)**  
**Rotating Speed: 5100 RPM**  
**Overall Alarm: 0.400 ips**


## 2015 FEA Analysis

- ➡ 1 44.0 Hz Lateral RBM
- ➡ 2 53.3 Hz Axial RBM
- ➡ 3 \*\*\*
- ➡ 4 70.7 Hz Vert Pitch Mode
- ➡ 5 92.0 Hz Torsional Mode
- ➡ 6 106 Hz Torsional Mode

## Pre-Shutdown Analysis & Testing

Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2%
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (y,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

- (1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]  
(2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed  
(3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements  
(4) 2015 OMA Analysis (Impulse) Operating EMA Analysis  
(5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results  
(\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending  
(\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.



**Machine Class: Feed Water Pump (Nuclear)**  
**Rotating Speed: 5100 RPM**  
**Overall Alarm: 0.400 ips**


## 2015 FEA Analysis

### Pre-Shutdown Analysis & Testing

Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2%
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (y,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

- (1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]  
(2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed  
(3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements  
(4) 2015 OMA Analysis (Impulse) Operating EMA Analysis  
(5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results  
(\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending  
(\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.

- ➔ 1 44.0 Hz Lateral RBM  
➔ 2 53.3 Hz Axial RBM  
3 \*\*\*  
➔ 4 70.7 Hz Vert Pitch Mode  
➔ 5 92.0 Hz Torsional Mode  
➔ 6 106 Hz Torsional Mode



Machine Class: Feed Water Pump (Nuclear)  
 Rotating Speed: 5100 RPM  
 Overall Alarm: 0.400 ips


## 2015 FEA Analysis

- ➡ 1 44.0 Hz Lateral RBM
- ➡ 2 53.3 Hz Axial RBM
- 3 \*\*\*
- ➡ 4 70.7 Hz Vert Pitch Mode
- ➡ 5 92.0 Hz Torsional Mode
- ➡ 6 106 Hz Torsional Mode

## Pre-Shutdown Analysis & Testing

Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2%
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (y,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

- (1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]  
 (2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed  
 (3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements  
 (4) 2015 OMA Analysis (Impulse) Operating EMA Analysis  
 (5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results  
 (\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending  
 (\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.



Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips


## 2015 FEA Analysis

- ➡ 1 44.0 Hz Lateral RBM
- ➡ 2 53.3 Hz Axial RBM
- ➡ 3 \*\*\*
- ➡ 4 70.7 Hz Vert Pitch Mode
- ➡ 5 92.0 Hz Torsional Mode
- ➡ 6 106 Hz Torsional Mode

## Pre-Shutdown Analysis & Testing

Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2%
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (v,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

- (1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]  
(2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed  
(3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements  
(4) 2015 OMA Analysis (Impulse) Operating EMA Analysis  
(5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results  
(\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending  
(\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.





Machine Class: Feed Water Pump (Nuclear)  
 Rotating Speed: 5100 RPM  
 Overall Alarm: 0.400 ips


## 2015 FEA Analysis

- ➡ 1 44.0 Hz Lateral RBM
- ➡ 2 53.3 Hz Axial RBM
- ➡ 3 \*\*\*
- ➡ 4 70.7 Hz Vert Pitch Mode
- ➡ 5 92.0 Hz Torsional Mode
- ➡ 6 106 Hz Torsional Mode

## Pre-Shutdown Analysis & Testing

Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2%
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (v,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

- (1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]  
 (2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed  
 (3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements  
 (4) 2015 OMA Analysis (Impulse) Operating EMA Analysis  
 (5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results  
 (\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending  
 (\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.



Machine Class: Feed Water Pump (Nuclear)  
 Rotating Speed: 5100 RPM  
 Overall Alarm: 0.400 ips


## 2015 FEA Analysis

- ➡ 1 44.0 Hz Lateral RBM
- ➡ 2 53.3 Hz Axial RBM
- ➡ 3 \*\*\*
- ➡ 4 70.7 Hz Vert Pitch Mode
- ➡ 5 92.0 Hz Torsional Mode
- ➡ 6 106 Hz Torsional Mode


## Pre-Shutdown Analysis & Testing

Mode	Mode Shape	2005 EMA <sup>(1)</sup> Analysis	FEA BL 2015 <sup>(2)</sup> [w/ Gussets]	2015 OMA <sup>(3)</sup> [Impulse]	2015 OMA <sup>(4)</sup> [non-Impulse]	FEA BL 2015 <sup>(5)</sup> [Correlation]
1	Lateral RBM*(y)	37.7 Hz	44.0 Hz	46.5 Hz	45.6 Hz	3.6%
2	Axial RBM*(x)	43.7 Hz	53.3 Hz	49.2 Hz	51.3 Hz	3.9%
3	Vertical RBM*(z)	**	**	**	**	**
4	Vertical Pitch (z)	69.9 Hz	70.7 Hz	85.3 Hz	85.0 Hz	20.2%
5	Torsion (z)	85.2 Hz	92.0 Hz	92.2 Hz	91.9 Hz	0.2%
6	Torsion (y,z)	98.3 Hz	106 Hz	99.0 Hz	103 Hz	2.8%

- (1) 2005 EMA Test Conditions [Cold, Coupled, Dewatered, All Piping Attached]  
 (2) 2015 FEA Analysis based on 2005 Geometry and 2014 Pedestal Gussets Modification Installed  
 (3) 2015 OMA Analysis (Non-Impulse) de-convolution of the ME'scope ODSFRF® measurements  
 (4) 2015 OMA Analysis (Impulse) Operating EMA Analysis  
 (5) FEA Baseline analysis Correlation with OMA (Impulse) and OMA (Non-Impulse) Results  
 (\*) RBM denotes Rigid Body Mode. Typically, in-phase translational motion (x, y, z) without significant bending  
 (\*\*) The Vertical RBM (bounce) was not detected in the 2005 EMA data & below detection in the OMA data.




Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips



Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

## 2015 EXPERIMENTAL MODAL ANALYSIS



**VERIFY** Natural Frequencies and Mode Shapes during Maintenance Outage (OR17)  
Shutdown Experimental Modal Analysis




Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
<b>4</b>	<b>Vertical Pitch (z)</b>	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>


(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered]

## 2015 EMA Analysis Pre-modifications

- 1 47.4 Hz
- 2 51.2 Hz
- 3 72.9 Hz
- 4 83.7 Hz
- 5 97.0 Hz
- 6 106 Hz




## 2015 EMA Analysis – Modal Frequency Variations

1	47.4 Hz
2	51.2 Hz
3	72.9 Hz
4	83.7 Hz
5	97.0 Hz
6	106 Hz

- Temperature
- Water Load
- Coupling
- Piping Removed
- Plating

All Modes out of  
resonant range  
except VPM





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
4	Vertical Pitch (z)	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]





Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
4	Vertical Pitch (z)	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]


Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips


## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



View: 3D View  
[Normal Shape]  
SHP: 2015 EMA FWP32B Composite Shapes  
Freq: 49.814 (Hz)  
Damp: 2.1473%

**RBM x**



FSDiagnostics.com

## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
4	Vertical Pitch (z)	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]


Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips


## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



View: 3D View  
[Normal Shape]  
SHP: 2015 EMA FWP32B Composite Shapes  
Freq: 71.534 (Hz)  
Damp: 2.1757%

**RBM z**



FSDiagnostics.com

## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
4	Vertical Pitch (z)	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]




Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips


## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



View: 3D View  
[Normal Shape]  
SHP: 2015 EMA FWP32B Composite Shapes  
Freq: 81.726 (Hz)  
Damp: 2.2668%

**VPM z**



FSDiagnostics.com

## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
4	Vertical Pitch (z)	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]




Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips


## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode



View: 3D View  
[Normal Shape]  
SHP: 2015 EMA FWP32B Composite Shapes  
Freq: 91.375 (Hz)  
Damp: 1.8936%

**TOR z,y**



FSDiagnostics.com

## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	<b>47.4 Hz</b>
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	<b>51.2 Hz</b>
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	<b>72.9 Hz</b>
4	Vertical Pitch (z)	<b>81.7 Hz</b>	<b>81.7 Hz</b>	<b>83.7 Hz</b>
5	Torsion (z)	91.4 Hz	90.6 Hz	<b>97.0 Hz</b>
6	Torsion (y, z)	97.0 Hz	97.5 Hz	<b>100 Hz</b>

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]

(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]


Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2015 EMA Analysis Pre-Modifications

- 1 47.4 Hz Lateral RBM
- 2 51.2 Hz Axial RBM
- 3 72.9 Hz Vertical RBM
- 4 83.7 Hz Vert Pitch Mode
- 5 97.0 Hz Torsional Mode
- 6 100 Hz Torsional Mode




## Post-Shutdown Analysis & Testing

Mode	Mode Shape	2015 EMA <sup>(1)</sup> [@ SD (hot)]	2015 EMA <sup>(2)</sup> [@ SD (cold)]	2015 EMA BL <sup>(3)</sup> [@SD Dewater]
1	Lateral RBM* (y)	46.0 Hz	46.7 Hz	47.4 Hz
2	Axial RBM* (x)	49.8 Hz	49.6 Hz	51.2 Hz
3	Vertical RBM* (z)	71.5 Hz	71.4 Hz	72.9 Hz
4	Vertical Pitch (z)	81.7 Hz	81.7 Hz	83.7 Hz
5	Torsion (z)	91.4 Hz	90.6 Hz	97.0 Hz
6	Torsion (y, z)	97.0 Hz	97.5 Hz	100 Hz

(1) EMA Test Oct 1, 2015 Conditions [Hot, Coupled, Full of Water, All Piping Attached]



(2) EMA Test Oct 2, 2015 Conditions [Cold, Coupled, Full of Water, All Piping Attached]

(3) EMA Baseline Test Oct 7, 2015 Conditions [Cold, Un-Coupled, Dewatered, Small Line Piping Removed]



Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

View: 3D View  
[Normal Shape]  
BLK: SEA FWP32B EMA DATA 2005  
Freq: 71 Hz





2005 EMA VPM z

70 Hz

Speed:10, Amp:5  
Full Spectrum Diagnostics

View: 3D View  
[Normal Shape]  
BLK: FPL SEA FWP32B EMA APR2015  
Freq: 84.4 Hz




2015 OMA VPM z

85 Hz

Speed:10, Amp:10  
Full Spectrum Diagnostics

View: 3D View  
[Normal Shape]  
SHP: 2015 EMA FWP32B Composite Shapes  
Freq: 81.726 (Hz)  
Damp:2.2868%

2015 EMA VPM z




81.7 Hz

FSDiagnostics.com

Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

## 2015 STRUCTURAL MODIFICATIONS






**VERIFY** Natural Frequencies and Mode Shapes during Maintenance Outage (OR17)  
Shutdown Experimental Modal Analysis  
Post-Modification EMA




Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips


## 2015 STRUCTURAL MODIFICATIONS




Trial #1




Trial #2



Trial #3



Trial #4




Trial #5

Machine Class: Feed Water Pump (Nuclear)  
 Rotating Speed: 5100 RPM  
 Overall Alarm: 0.400 ips

## 2015 EMA Analysis Post Plating Modifications

- 1 49.1 Hz
- 2 52.1 Hz
- 3 74.5 Hz
- 4 86.9 Hz [Plating  $\Delta$  3.2 Hz]**
- 5 97.4 Hz
- 6 104 Hz



### EMA Correlated FEA / SDM Plating (stiffening) Analysis

Mode	Mode Shape	SDM Plating <sup>(3)</sup> [EMA BL Projected]	2015 EMA <sup>(4)</sup> [Final Plating]
1	Lateral RBM* (y)	58.9 Hz	49.1 Hz
2	Axial RBM* (x)	74.8 Hz	52.1 Hz
3	Vertical RBM* (z)	75.3 Hz	74.5 Hz
4	<b>Vertical Pitch (z)</b>	<b>96.8 Hz</b>	<b>86.9 Hz</b>
5	Torsion (z)	92.3 Hz	97.4 Hz
6	Torsion (y, z)	113 Hz	104 Hz

(3) SDM Plating Projection based on Baseline EMA analysis



(4) EMA Test Final Plating Complete Oct 16, 2015

Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## 2015 ALIGNMENT GUIDE BARREL LUGS




**DIGGING DEEPER** Searching for the Discrepancies in the Analysis vs. Data  
Potential External Forces on Pump  
Piping / Foundation / Alignment Guide Lugs

Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

## Attained Approval to “Un-Lock” the Alignment Guide Barrel Lugs






Machine Class: Feed Water Pump (Nuclear)  
 Rotating Speed: 5100 RPM  
 Overall Alarm: 0.400 ips

## 2015 EMA Analysis Post-Modifications Lugs Released

- 1 44.1 Hz
- 2 50.6 Hz
- 3 70.6 Hz
- 4 76.8 Hz [ $\Delta f$ : -11.6%]**
- 5 102 Hz
- 6 109 Hz



### EMA Correlated FEA / SDM Plating (stiffening) Analysis

Mode	Mode Shape	SDM Plating <sup>(3)</sup> [EMA BL Projected]	2015 EMA <sup>(4)</sup> [Final Plating]	2015 EMA <sup>(5)</sup> [Lugs Released]
1	Lateral RBM* (y)	58.9 Hz	49.1 Hz	44.1 Hz
2	Axial RBM* (x)	74.8 Hz	52.1 Hz	50.6 Hz
3	Vertical RBM* (z)	75.3 Hz	74.5 Hz	70.6 Hz
4	<b>Vertical Pitch (z)</b>	<b>96.8 Hz</b>	<b>86.9 Hz</b>	<b>76.8 Hz</b>
5	Torsion (z)	92.3 Hz	97.4 Hz	102 Hz
6	Torsion (y, z)	113 Hz	104 Hz	109 Hz


(3) SDM Plating Projection based on Baseline EMA analysis [Cold, Uncoupled, Dewatered]

(4) EMA Test Final Plating Complete Oct 16, 2015

(5) EMA Test Final Plating Complete, Alignment Guide Lugs Released Oct 18, 2015.

2015 EMA  
Analysis – Plated  
Lugs Relaxed

- 1 44.1 Hz
- 2 50.6 Hz
- 3 70.6 Hz
- 4 76.8 Hz**
- 5 102 Hz
- 6 109 Hz




























Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

### Pump Alignment Centering Lug Sensitivity Testing

Test Case	Load <sup>(1)</sup> Configuration	Natural Frequency	Shift Frequency	Alignment <sup>(2)</sup> Effect	Matrix Load Diagram	
0	Unloaded	77.7 Hz		0.0000		
1	SE Lug	84.1 Hz	+6.40 Hz	0.0007 W		
2	SE/NE Lugs	89.2 Hz	+11.5 Hz	0.0010 W		
3	NW/SE Lugs	89.5 Hz	+11.8 Hz	0.0007 W		
4	NW Lug	81.6 Hz	+3.90 Hz	0.0000		
5	NW/SW Lug	89.4 Hz	+11.7 Hz	0.0004 E		
6	SW Lug	82.0 Hz	+4.30 Hz	0.0004 E		
7	NE/SW Lugs	89.1 Hz	+11.4 Hz	0.0000		
8	NE Lug	81.4 Hz	+3.70 Hz	0.0003 W		
9	Unloaded	77.9 Hz	+0.20 Hz	0.0000		
10	All Hand Tight	80.0 Hz	+2.30 Hz	0.0000		




(1) All Loadings were Hand Tight + 1 Flat Engagement

(2) Alignment was monitored Real Time. Dimensions are inches

Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips

Sensitivity Testing proved that the Lug Loading induced a significant change in the response of the Vertical Pitching Mode ( $VPM_z$ ).

Testing indicated that the  $VPM_z$  natural frequency was potentially “tunable”.






**Machine Class: Feed Water Pump (Nuclear)**  
**Rotating Speed: 5100 RPM**  
**Overall Alarm: 0.400 ips**

# 2015 UNIT START-UP


**PERFORM** Start-up Operating Modal Analysis (OMA) on FW-P-32B  
Monitor Natural Frequencies, Mode Shapes  
Verify Modification Results

## Added Potential “Tuning” Decision Matrix



Machine Class: Feed Water Pump (Nuclear)  
Rotating Speed: 5100 RPM  
Overall Alarm: 0.400 ips


## Decision Matrix Summary



**Natural Frequency  
Below 1x RPM**

**Response Exceeds Limits**


**Unload Lugs to Reduce  
Stiffness / Attain Margin**



**Natural Frequency  
@ 1x RPM**

**Response Exceeds Limits**

**Load or Unload Lugs as  
required to Attain Margin**



**Natural Frequency  
Above 1x RPM**

**Response Exceeds Limits**

**Load Lugs to Increase  
Stiffness / Attain Margin**


Machine Class: Feed Water Pump (Nuclear)

Rotating Speed: 5100 RPM

Overall Alarm: 0.400 ips

100% Power – Acceptable Response

60% Reduction in Vertical Vibration @ Outboard Bearing



**Machine Class: Feed Water Pump (Nuclear)****Rotating Speed: 5100 RPM****Overall Alarm: 0.400 ips**

DATE	CONDITION	NAT FREQ	AMPL FACTOR	
15APR15	100% OMA (Impulse)	5,118	0.700 ips	
15APR15	100% OMA (Non-Impulse)	5,100	0.700 ips	
01OCT15	S/D Hot EMA	81.7 Hz	Q = 21.4	
02OCT15	S/D Cold EMA	81.7 Hz	Q = 21.4	
07OCT15	S/D Cold, Uncap, Dwater	83.7 Hz	Q = 20.1	Damping Increase Due to Plating
16OCT15	S/D Plating Complete	86.9 Hz	Q = 17.7	
18OCT15	S/D AG Lugs Relaxed	76.8 Hz	Q = 24.0	
07NOV15	S/D Lug Sens (0,9)	77.5 Hz	Q = 17.1	Damping Lugs Disengaged
07NOV15	S/D Lug Sens (2,3,5,7)	82.4 Hz	Q = 10.9	
07NOV15	S/D Lug Sens (1,4,6,8)	87.9 Hz	Q = 11.5	
08NOV15	S/D Final Alignment	80.0 Hz	Q = 13.9	Damping Lugs "Hand Tight"
15NOV15	S/D Filler w/Water	78.0 Hz	***	


DATE	CONDITION	1x RPM	AMP (ips)
16NOV15	Start 80.0% Power	4,536	0.278 ips
17NOV15	Start 89.7% Power	4,730	0.380 ips
17NOV15	Start 91.7% Power	4,779	0.310 ips
17NOV15	Start 92.2% Power	4,827	0.270 ips
17NOV15	Start 93.7% Power	4,867	0.280 ips
17NOV15	Start 93.7% Power	4,870	0.290 ips
17NOV15	Start 93.7% Power	4,866	0.280 ips
17NOV15	Start 93.9% Power	4,870	0.280 ips
17NOV15	Start 100% Power	5,037	0.225 ips



**Machine Class: Feed Water Pump (Nuclear)**

**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**



**November 2015 Startup 100% Power (8.1% Resonance Margin)**

**Natural Frequency: 78.1 Hz (4,686 CPM)**

**Operating Speed: 85.0 Hz (5,100 RPM)**


**1x RPM Amplitude at 85 Hz: 0.225 ips**

**Resonance Margin: 8.1%**

**Machine Class: Feed Water Pump (Nuclear)**

**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**



**March 2017 Operating @ 100% Power (0.420 ips) (4.5% Resonance Margin)**

**Natural Frequency: 81.2 Hz (4,872 CPM)**

**Operating Speed: 85.0 Hz (5,100 RPM)**


**1x RPM Amplitude at 85 Hz: 0.420 ips**

**Resonance Margin: 4.5%**

**Machine Class: Feed Water Pump (Nuclear)**

**Rotating Speed: 5100 RPM**

**Overall Alarm: 0.400 ips**



**March 2017 100% Pwr Lugs Released (0.240 ips) (7.5% Resonance Margin)**

**Natural Frequency: 78.6 Hz (4,716 CPM)**

**Operating Speed: 85.0 Hz (5,100 RPM)**

**1x RPM Amplitude at 85 Hz: 0.240 ips**

**Resonance Margin: 7.5%**

# Vibrant Technology's ME'scope

- Operating Deflection Shape (ODS) Analysis
- Experimental Modal Analysis (EMA)
- Operating Modal Analysis (OMA)
- Structural Dynamic Modification (SDM)
- Finite Element Analysis (FEA)
- FRF Synthesis